

# CERTIFICATE

This certifies, that the company

**Gefran S.p.A.**  
**Via Sebina, 74**  
**25050 Provaglio d'Iseo (BS)**  
**Italy**

Is authorized to provide the product mentioned below

Description of product: **Melt pressure sensor series IMPACT ILI-x-x-x-xxxx-x-x-x-P-xxxxxxxxxxx**

In accordance with: **IEC/EN 62061:2005 + A1:2013 + A2:2015 + EN 62061 / EC:2010**  
**IEC 61508:2010 Parts 1, 2, 3, 4, 5, 6, 7**  
**IEC 61511-1:2016 + A1:2017, IEC 61511-2, 3:2016 (as far as applicable)**  
**EN ISO 13849-1:2015**  
**EN ISO 13849-2:2012**

Registration No 21 22064 04  
Test Report No PS-22064-21-L-04  
File reference 22064-04



TÜV NORD Italia S.r.l. (TÜV NORD Group)  
Via Turati, 70 - 20023 Cerro Maggiore (MI)



[www.tuev-nord.it](http://www.tuev-nord.it)

Validity  
from 2021-12-22  
until 2024-12-22

Cerro Maggiore, 2021-12-22  
[prodotto@tuev-nord.it](mailto:prodotto@tuev-nord.it)

Please also pay attention to the information stated overleaf

TNI-QF(IND-SIL-01)-14-Rev00\_01\_03\_2020-Certificate\_Type A

# ANNEX

Annex 1, Page 2 of 2

To Certificate-Nr. 21 22064 04

<b>Safety functions</b>	1. Analog output (current or voltage) 2. Relay output (de-energise to trip)
<b>Mode of operation</b>	High Demand Mode

Results		
Parameter	Value	Measuring Unit
Architecture	1001 (1002 for relay output block)	--
HFT	0 (1 for relay output block)	--
Category	2 (3 for relay output block)	--
$\beta, \beta_D$ factors	0,02	--
$\lambda_{DD}$		
Analog output	4,61E-07	1/h
Relay output	4,44E-07	1/h
$\lambda_{DU}$		
Analog output	6,73E-08	1/h
Relay output	3,72E-08	1/h
$DC_{avg}$		
Analog output	90	%
Relay output	90	%
SFF		
Analog output	94,1	%
Relay output	96,7	%
$MTTF_D$		
Analog output	216	years
Relay output	237	years
$PFH / PFH_D$		
Analog output	6,73E-08	1/h
Relay output	3,72E-08	1/h
Systematic Capability	2	--
SILCL (IEC/EN 62061)	2	--
SIL (IEC/EN 61508)	2	--
PL (EN ISO 13849)	d	--

The product can be declared as compliant to:	<b>IEC/EN 62061 SILCL 2, IEC/EN 61508 SIL 2, EN ISO 13849-1, EN ISO 13849-2, PL d</b>
--	---

<b>Remarks:</b>	<ul style="list-style-type: none"> <li>• These results must be considered in combination with SIL/PL and <math>\lambda_D</math> values of other devices of a safety-related system in order to determine suitability for a specific SIL/PL</li> <li>• The results are "worst case" results, considering all the mechanical versions</li> <li>• The results for analog output are conservative "worst case" results for voltage or current output</li> </ul>
-----------------	---

